

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014553.01-R1
DATE: 11/19/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Plyco
CODE: 765-1
REVISION DATE: 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Plyco Corporation dba Modern Door Corporation 500 Industrial Road/PO Box 386 Elkhart Lake, WI 53020	"4070 Series 20 EV" Opaque Out-Swing Steel Side-Hinged Door w/Single Lock and Deadbolt Engaged Configuration: X Frame: W-1318mm(51.88") H-2169mm(85.38") Panel: W-1213mm(47.75") H-2112mm(83.13")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14	Design Pressure: 2155 Pa (45 psf)

Product Tested By: Element Materials Technology, Inc.
Report No: ESP031518P-2458.3
Expiration Date: August 31, 2026

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com