

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014553.05-R1  
**DATE:** 11/19/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Plyco  
**CODE:** 765-1  
**REVISION DATE:** 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Plyco Corporation</b> <b>dba Modern Door Corporation</b> <b>500 Industrial Road/PO Box 386</b> <b>Elkhart Lake, WI 53020</b>	<b>"4070 Series 20 EV"</b> <b>Opaque Out-Swing Steel</b> <b>Side-Hinged Door</b>  w/Panic Bar Hardware Configuration: X  Frame: W-1318mm(51.88") H-2169mm(85.38") Panel: W-1213mm(47.75") H-2111mm(83.13")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b>	<b>Design Pressure: 960 Pa (20 psf)</b> <b>Positive Design Pressure: 1200 Pa (25 psf)</b> <b>Negative Design Pressure: 960 Pa (20 psf)</b>

Product Tested By: Element Materials Technology, Inc.  
Report No: ESP031518P-2458.8  
Expiration Date: August 31, 2026

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)