

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010941-R4  
DATE: 01/30/2012  
CERTIFICATION PROGRAM: Structural  
COMPANY: LAS Enterprises  
CODE: 1124-1  
REVISION DATE: 07/13/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
LAS Enterprises 2413 L & A Road Metairie, LA 70001	Series "Colonial Standard" Aluminum Shutter Assembly  Configuration: X/X  Frame: W-1067mm (42")    H-2134mm (84")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-05/E1996-05	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-2078W  
Expiration Date: **December 31, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)