



NOTICE OF PRODUCT CERTIFICATION

Company: JELD-WEN Doors
 3737 Lakeport Drive
 Klamath Falls, OR 97601

Certification No.: NI011064-R3
Certification Date: 04/18/2012
Expiration Date: 04/30/2026
Revision Date: 10/12/2016

Product: 24 Ga. Steel Wood Edge Glazed & Opaque Doors w/Glazed Sidelites (w/wood frame)

Specification: ASTM E283-04/E330-02/E331-00/AAMA 1304-02

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Test Report Number Drawing Number & Comments
OXXO Double w/Sidelites	I/S	Door-Glazed Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/NCTL 210-3801-1/FL 1940/W-1788 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-276 Sill Installation Details: JW152012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	I/S	Door-Glazed Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/SJW2010-146/FL 1940/W-1788 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/Endura LZA1L5625DSR Sill Installation Details: JW152012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	O/S	Door-Glazed Sidelite-Glazed	12'5" x 8'1"	+35/-35 psf	NCTL 210-3804-4/NCTL 210-3801-1/FL 1940/W-1788 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-117 Sill Installation Details: JW152012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/NCTL 210-3801-1/FL 1938/W-1788 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-276 Sill Installation Details: JW142012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/SJW2010-146/FL 1938/W-1788 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/Endura LZA1L5625DSR Sill Installation Details: JW142012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	12'5" x 8'1"	+35/-35 psf	NCTL 210-3804-4/NCTL 210-3801-1/FL 1938/W-1788 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-117 Sill Installation Details: JW142012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be "MJD", is written over the signature line.