NOTICE OF PRODUCT CERTIFICATION '



CERTIFICATION NO: NI005843-R7

DATE: 11/05/2004

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: Kennedy

CODE: 1978-1

REVISION DATE: 06/20/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kennedy Skylights	Model "CM" Curb Mounted
5294 Tower Way	Polycarbonate Skylight
Sanford, FL 32773	
	Dome-0.093"/Inner Dome-0.040"
	STP PSF
	Frame: W-4'4" Opening: W-4'1" Pos+120.0
	Panel: H-4'4" Opening: W-4'1" Neg-120.0

SPECIFICATION	PRODUCT RATING
AAMA/WDMA 1600/I.S.7-2000	SKP-C60 60 (52 x 52)

Product Tested By: National Certified Testing Laboratories, Inc.

Report No: NCTL-210-3042-2/3 (Structural)

Expiration Date: July 31, 2024

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: nami@namiinc.com