

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005844-R6
DATE: 11/05/2004
CERTIFICATION PROGRAM: Structural
COMPANY: Kennedy
CODE: 1978-1
REVISION DATE: 07/28/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kennedy Skylights 5294 Tower Way Sanford, FL 32773	Model "SF" Self Flashing Polycarbonate Skylight Dome-0.093"/Inner Dome-0.040" <u>STP PSF</u> Frame: W-4'6" Opening: W-3'11" Pos+175.0 Panel: H-4'6" Opening: W-3'11" Neg-140.0

SPECIFICATION	PRODUCT RATING
AAMA/WDMA 1600/L.S.7-2000	SKP-C85 70 (54" x 54")

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-210-3042-1 (Structural)
Expiration Date: **August 31, 2024**

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122