NOTICE OF PRODUCT CERTIFICATION

1065 ACCREDITED AS		
W LOTAL AUCHEDITY ROC	CERTIFICATION NO:	NI005962-R9
So In the second	DATE:	11/30/2004
	CERTIFICATION PROGRAM:	Structural
A REAL PROVIDENCE OF THE REAL PROVIDENCE OF T	COMPANY:	Kennedy
Conderment INSTIT	CODE:	1978-1
CATIFIED PRODUC	REVISION DATE:	06/04/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODU	UCT DESCRIPT	ΓΙΟΝ
Natural Light Energy Systems	Model "CMG" Curb Mounted		
dba Kennedy Skylights	Glass Skylight		
5294 Tower Way			
Sanford, FL 32773	Glazing: Insulating Glass (Tempered)		
			STP PSF
	Frame: W-4'3"	Opening: W-3'7"	Pos+195.0
	H-4'3"	H-3'7"	Neg-195.0

SPECIFICATION	PRODUCT RATING
AAMA/WDMA 1600/I.S.7-2000	SKG-C95 95 (51" x 51")

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories, Inc. NCTL-210-3041-3A (Structural) August 31, 2029

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>

NOPC-03/30/2023