

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI009833-R8  
**DATE:** 02/26/2009  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Kennedy  
**CODE:** 1978-1  
**REVISION DATE:** 09/25/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>Natural Light Energy Systems</b><br><b>dba Kennedy Skylights</b><br><b>5294 Tower Way</b><br><b>Sanford, FL 32773</b> | <b>Model "ISFG4" Aluminum Clad Curb</b><br><b>Mounted Self-Flashing Glass Skylight</b><br><br>Glazing: IG-1/8" Tempered Glass/Laminate-1/8"<br>Annealed Glass/0.090" Kuraray Trosifol<br>Interlayer/1/8" Annealed Glass<br><br>Frame: W-1403mm(55.25") H-1403mm(55.25")<br>DLO: W-1092mm(43.00") H-1092mm(43.00") |

| SPECIFICATION   | PRODUCT RATING   |
|---|--|
| <b>ASTM E283-91/E330-90/E331-93</b><br><b>ASTM E1886-99/1996-99</b> | <b>Design Pressure: +52.5/-52.5 psf</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: National Certified Testing Laboratories, Inc.  
Report No: NCTL-210-2959-1 (Structural)  
Expiration Date: **October 31, 2029**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023