

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011257.02-R4  
**DATE:** 10/03/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "4880IR" Impact Rated</b> <b>Aluminum Sliding Glass Door</b>  Configuration: XXXX Glazing: IG-Laminate-3/16" Heat Strengthened Glass/ 0.075" Saflex Vanceva Interlayer/3/16" Heat Strengthened Glass/5/32" Tempered Glass  Frame: W-4715mm(185.63") H-2432mm(95.75") Panel: W-1238mm(48.75") H-2394mm(94.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-06/16</b> <b>ASTM E1886-05/19/E1996-09/20</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Design Pressure: ±3352 Pa (70 psf)</b> <b>Wind Zone 3-Missile Level D</b> <b>Class LC-PG70 4715 x 2432 (186 x 96)-SD</b> Water Penetration Resistance Test Pressure: Sill Riser #12457: 504 Pa(10.5 psf)

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI-12-173/W-2010  
Expiration Date: September 30, 2027

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)