

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011257.03-R6
DATE: 10/03/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4880IR" Impact Rated Aluminum Sliding Glass Door Configuration: XXXX Glazing: IG-Laminate-3/16" Heat Strengthened Glass/ 0.075" Saflex Vanceva Interlayer/3/16" Heat Strengthened Glass/5/32" Tempered Glass Frame: W-4715mm(185.63") H-2432mm(95.75") Panel: W-1238mm(48.75") H-2394mm(94.25")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/16 ASTM E1886-05/19/E1996-09/20 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Design Pressure: ±2394 Pa (50 psf) Wind Zone 3-Missile Level D Class LC-PG50 4715 x 2432 (186 x 96)-SD Negative Design Pressure Rating: 3352 Pa (70 psf) Water Penetration Resistance Test Pressure: Sill Riser #12342: 360 Pa(7.5 psf)

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI-12-173/W-2010
Expiration Date: September 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com