

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011283-R4  
DATE: 09/25/2012  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1  
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic Avenue</b> <b>Ft. Myers, FL 33912</b>	<b>Series "143" Vinyl Fin Frame</b> <b>or Equal Leg Frame Impact Rated</b> <b>Awning Window</b>  Configuration: X Glazing: IG-1/8" Annealed Glass/Laminate- 1/8" Annealed Glass/0.075" Eastman Chemical PVB Interlayer/1/8" Annealed Glass  Frame: W-1349mm(53.13") H-991mm(39")  Vent: W-1308mm(51.5") H-953mm(37.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-08</b> <b>ASTM E1886-05/E1996-06</b> <b>TAS 201/202/203-94</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Design Pressure: +65/-70 psf</b> <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b> <b>AP-C70 1346 x 991 (53 x 39)</b>

Product Tested By: Element Materials Technology  
Report No: ESP101311P/ESP10311P-1/ESP10311P-2/ESP10311P-3  
Expiration Date: **June 30, 2027**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023