

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011286.03-R1  
**DATE:** 04/12/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 08/22/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic</b> <b>Ft. Myers, FL 33913</b>	<b>Series "FWI 1000 Horizontal Roller"</b> <b>Aluminum Un-Equal Lite</b> <b>Horizontal Sliding Window</b>  Configuration: XOX Glazing: IG - 1/8" Annealed Glass/1/8" Annealed Glass/0.090"Saflex PVB Interlayer/1/8" Annealed Glass or Monolithic - 1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass  Frame: W-2819mm(111") H-1930mm(76") Panel: W-706mm(27.81") H-1819mm(71.63") DLO: W-1311mm(51.63") H-1808mm(71.19")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-13a/E1996-14a</b> <b>TAS 201/202/203-94</b>	<b>Design Pressure: ±2873 Pa (±60 psf)</b> <b>Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf)</b> <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Technical Services, Inc.  
Report No: BT-EAS-20-002/W-2044  
Expiration Date: March 31, 2025

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)