

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011287.01-R1
DATE: 04/12/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 08/22/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912 | Series "FWI 1000 Horizontal Roller" Aluminum Horizontal Sliding Window Configuration: OX Glazing: IG - 1/8" Annealed Glass/1/8" Annealed Glass/0.090"Saflex PVB Interlayer/1/8" Annealed Glass or Monolithic - 1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1880mm(74") H-1930mm(76") Panel: W-945mm(37.19") H-1819mm(71.63") DLO: W-865mm(34.06") H-1808mm(71.19") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| ASTM E1886-13a/E1996-14a TAS 201/202/203-94 | Design Pressure: ±2873 Pa (±60 psf) Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated |

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-EAS-20-002/W-2044
Expiration Date: March 31, 2025

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com