

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.08-R8
DATE: 12/05/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/01/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Vinyl Tilt Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1119mm(44.06") H-1959mm(77.13") Sash: W-1051mm(41.38") H-953mm(37.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG35 1119 x 1959 (44 x 77)-H H-LC35 1119 x 1959 (44 x 77) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15602-1/W-1717/W-1758/W-1831/W-1867
Expiration Date: **October 31, 2026**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com