

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.12-R5
DATE: 12/19/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/09/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Vinyl Tilt Single Hung Window Configuration: O/X Glazing: IG-1/8" Annealed Glass (Interior)/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass (Exterior) Frame: W-967mm(38.06") H-1957mm(77.06") Sash: W-900mm(35.44") H-954mm(37.56")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09 ASTM E1886-02/05/13a/E1996-02/05/12a	Overall Design Pressure: +50/-60 psf Wind Zone 3-Missile Level D Class LC-PG50 967 x 1957 (38 x 77)-H H-LC50 967 x 1957 (38 x 77) Negative Design Pressure: 2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15653-2/NCTL-110-15653-1/W-1758/W-1867/W-1958
Expiration Date: November 30, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com