

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.16-R6  
DATE: 04/22/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 10/24/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Ply Gem 1500"</b><br><b>Vinyl Tilt Single Hung Window</b><br><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1346mm(53") H-1959mm(77.13")<br>Sash: W-1279mm(50.38") H-954mm(37.56") |

| SPECIFICATION  | PRODUCT RATING   |
|--|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b><br><b>CSA A440S1-09</b> | <b>Class LC-PG40 1346 x 1959 (53 x 77)-H</b><br><b>H-LC40 1346 x 1959 (53 x 77)</b><br><b>Design Pressure: 1920 Pa (40 psf)</b><br><b>Negative Design Pressure: 1920 Pa (40 psf)</b><br>Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)<br>Canadian Air Infiltration/Exfiltration Level: A2 |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-16029-1/110-15597-1/W-1717/W-1758/W-1831/W-1867/  
W-2047  
Expiration Date: March 31, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)