NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.30-R2

DATE: 10/03/2019

CERTIFICATION PROGRAM: Structural

COMPANY: Ply Gem

CODE: 1408-1

REVISION DATE: 11/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group	"Ply Gem 1500" Impact Rated
433 North Main Street	Vinyl Tilt Single Hung Window
Rocky Mount, VA 24151	
	Configuration: O/X Glazing: IG-Exterior-1/8" Annealed Glass/ Interior-Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass
	Frame: W-1324mm(52.13") H-1803mm(71")
	Sash: W-1259mm(49.56") H-762mm(30")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 ASTM E1886-05/13a/E1996-02/05/12a AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Design Pressure: +50/-50 psf Wind Zone 3-Missile Level D Class LC-PG50 1324 x 1803* (52 x 71*)-H H-LC50 1324 x 1803* (52 x 71*) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-110-16416-3/NCTL-110-15597-1/NCTL-110-16029-1/NCTL-110-16245-1/W-1758/W-

1867/W-1958

Expiration Date: May 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com