

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013370.04-R5  
DATE: 09/17/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 01/16/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "1500"</b> <b>Vinyl Single Hung</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-900mm(35.44") H-1867mm(73.5") Sash: W-835mm(32.88") H-906mm(35.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b>	<b>Class LC-PG35 900 x 1867 (35 x 74)-H</b> <b>H-LC35 900 x 1867 (35 x 74)</b> <b>Design Pressure: ±1680 Pa (35 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19348-3/NCTL-110-19262-1/W-1831/W-1867/W-2112/W-2047  
Expiration Date: April 30, 2028

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)