

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013800-R3
DATE: 07/30/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/11/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "1500" Vinyl Single Hung Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1208mm(47.56") H-1511mm(59.5") Sash: W-1141mm(44.94") H-730mm(28.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class LC-PG50 1208 x 1511 (48 x 60)-H H-LC50 1208 x 1511 (48 x 60) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19792-1/NCTL-110-15598-1/W-1831/W-1867
Expiration Date: **December 31, 2024**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122