



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG55-1346x1930 (53x76)-H Negative Design Pressure = -60 psf	PA 201, 202, 203				
COMPANY	Missile Level: Large Rating: +55/-60, 53x76	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	Rating above conforms to requirements of: TAS 201, TAS 202 and TAS 203	12486	07-09 STORMBREAKER PLUS DOUBLE HUNG (PVC) (X/X) (OG) (INS TEMP/PVB LAM GL) (TILT) (MODIF) (REINF) (ASTM)	<u>FRAME(mm)</u> 1346 x 1930 (4'5" x 6'4")	<u>SASH(mm)</u> 1267 x 946 (4'2" x 3'1")

1. This Certification will expire **November 7, 2022 (extended from November 7, 2017 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Structural Test & Report By:

Missile Impact Test & Report by:

Architectural Testing, Inc.

Architectural Testing, Inc.

Report No: **D0965.01-501-47**

Report No: **D3024.01-501-18**

Date of Report: **November 15, 2013**

Date of Report: **January 10, 2014**

Evaluated for Certification: **April 19, 2017**

Bral Schultz
Associated Laboratories, Inc.

Authorized for Certification: **April 19, 2017**

John J. ...

American Architectural Manufacturers Association

SBS/JTS