

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011565.08-R6  
**DATE:** 05/23/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ProVia Door  
**CODE:** 1212-1  
**REVISION DATE:** 04/11/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>ProVia LLC</b>   <b>2150 State Route 39</b>   <b>Sugarcreek, OH 44681</b></p>	<p style="text-align: center;"><b>Steel Double In-Swing Glazed</b>   <b>Side Hinged Door w/Sidelites &amp; Transom</b></p> <p style="text-align: center;">                     Configuration: O over OXXO                      Glazing: IG-Exterior-1/8" Tempered Glass/                      Interior-Laminate-1/8" Annealed Glass/0.090" Solutia                      Interlayer/1/8" Annealed Glass or IG-Exterior-Laminate-1/8"                      Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed                      Glass/Center-1/8" Tempered Glass/Interior-1/8" Tempered Glass/                      IG-Exterior-1/8" Tempered Glass/Center-1/8" Tempered                      Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8"                      Annealed Glass or IG-Exterior-1/8" Tempered Glass/Center-                      Decorative Inlay/Interior-Laminate-1/8" Annealed Glass/0.090"                      Solutia Interlayer/1/8" Annealed Glass or                      IG-Exterior-1/8" Tempered Glass/Center-Wrought Iron Decorative                      Inlay/Interior-Laminate-1/8" Annealed Glass/0.090" Solutia                      Interlayer/1/8" Annealed Glass                 </p> <p style="text-align: center;">Frame: W-3321mm(130.78") H-2999mm(118.09")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"> <b>ASTM E283-04(12)/E330-02(10)/</b>  <b>ASTM E1886-04/05/E1996-02/04/06/09/12a</b> </p>	<p style="text-align: center;"> <b>Design Pressure: 2633 Pa (55 psf)</b>  <b>Wind Zone 3-Missile Level D</b> </p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-110-15660-1/NCTL-110-15660-2/W-1561/W-1573/W-2002/  
 W-2024  
 Expiration Date: **December 31, 2024**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION &**  
**MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)