

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011572.05-R5
DATE: 05/31/2013
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 05/09/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>ProVia Door, Inc. 2150 State Route 39 Sugarcreek, OH 44681</p>	<p>Steel In-Swing Opaque Side Hinged Double Door w/Sidelites & Transom Configuration: O over OXXO Glazing: IG-Exterior-1/8" Tempered Glass/ Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or IG-Exterior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass/Center-1/8" Tempered Glass/Interior-1/8" Tempered Glass/ IG-Exterior-1/8" Tempered Glass/Center-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or IG-Exterior-1/8" Tempered Glass/Center-Decorative Inlay/Interior- Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or IG-Exterior-1/8" Tempered Glass/Center-Wrought Iron Decorative Inlay/Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass</p> <p>Frame: W-3321mm(130.78") H-3310mm(130.34") Panel: W-908mm(35.75") H-2411mm(94.94")</p>

SPECIFICATION	PRODUCT RATING
<p>ASTM E330-02 ASTM E1886-04/05/E1996-02/04/06/09/12a</p>	<p>Design Pressure: 2633 Pa (55 psf) Wind Zone 3-Missile Level D Qualifies Configurations: O over OXX, O over XXO, O over OXXO</p>

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15660-1/NCTL-110-15660-2/NCTL-110-15650-2/NCTL-110-15650-4
 /NCTL-110-15651-2/NCTL-110-15651-4/NCTL-110-15652-2/NCTL-110-15652-3/
 W-1581
Expiration Date: December 31, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124 Fax: (804) 684-5122