

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012195
DATE: 11/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "176.043" Vinyl Single Hung Window w/Fin or Flange Frame Configuration: O/X Glazing: IG-Ext-3/16" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" SGP Interlayer by DuPont/1/8" Annealed Glass Frame: W-1372mm(54.00") H-1956mm(77.00") Panel: W-1334mm(50.37") H-940mm(37.75")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ± 3351 Pa (70 psf) Class LC-PG70 1372 x 1956 (54 x 77)-H H-LC70 1372 x 1956 (54 x 77) Positive Design Pressure: 3351 Pa (70 psf) Negative Design Pressure: 4069 Pa (85 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 502 Pa(10.50 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3005WA/CTLA-3005WD
Expiration Date: **June 30, 2018**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122