

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011460-R2  
DATE: 02/14/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: ProVia Door  
CODE: 1212-1  
REVISION DATE: 10/15/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia Door, Inc.</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>Series "Side Lite"</b> <b>Steel Fixed Side Lite Window</b>  Configuration: O Glazing: IG-Exterior-1/8" Tempered Glass/ Interior Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass  Frame: W-645mm(25.4") H-2479mm(97.6") DLO: W-314mm(12.4") H-1991mm(78.4")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05/08</b> <b>ASTM E283-04(12)/E330-02(10)/</b> <b>E331-00(09)/E547-00(09)</b> <b>ASTM E1886-04/05/E1996-02/04/06/09/12a</b>	<b>Class CW-PG55 645 x 2479 (25 x 98)-SLT</b> <b>SLT-C55 645-2479 (25 x 98)</b> <b>Design Pressure: 2640 Pa (55 psf)</b> <b>Wind Zone 3-Missile Level D</b> Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15650-1/NCTL-110-15650-2/NCTL-110-15650-4  
Expiration Date: **December 31, 2024**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/ Fax: (804) 684-5122