

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011461-R2
DATE: 02/14/2013
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 10/15/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia Door, Inc. 2150 State Route 39 Sugarcreek, OH 44681	Series "Transom" Composite Fixed Transom (Double & Triple Glazed) Configuration: O Double Glazing: IG-Exterior-1/8" Tempered Glass/ Interior Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or Triple Glazing: IG-Exterior-1/8" Tempered Glass/ Center-1/8" Tempered Glass/Interior Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/ 1/8" Annealed Glass Frame: W-2481mm(97.69") H-805mm(31.69") DLO: W-2405mm(94.69") H-729mm(28.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05/08 ASTM E283-04(12)/E330-02(10)/ E331-00(09)/E547-00(09) ASTM E1886-04/05/E1996-02/04/06/09/12a	Class CW-PG55 2480 x 805 (98 x 32)-TR TR-C55 2480 x 805 (98 x 32) Design Pressure: 2633 Pa (55 psf) Wind Zone 3-Missile Level D Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15652-1/NCTL-110-15652-2/NCTL-110-15652-3
Expiration Date: **December 31, 2024**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124 Fax: (804) 684-5122