

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
1955 Powis Road
West Chicago, IL 60185

Certification No.: NI006039.01
Certification Date: 05/31/2005
Expiration Date: 02/28/2021
Revision Date: 02/20/2015

Product: Metal-Edge Impact Rated Steel Door w/"Fast Frame" Two Piece Adjustable Steel Frame

Specification: TAS 201/202/203-94

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single (Slabs-CA/CH/EN)	I/S	Opaque	3'3" x 6'10"	+66/-66	2.86 psf	Yes	NCTL-210-3090-1 Max Panel Size: 3'0" x 6'7" Anchor Details: MA-FL0178
X Single (Slabs-CA/CH/EN)	O/S	Opaque	3'3" x 6'9"	+66/-66	10.5 psf	Yes	NCTL-210-3090-1 Max Panel Size: 3'0" x 6'7" Anchor Details: MA-FL0178
X Single (Slabs-CA/CH/EN)	I/S	Opaque	3'3" x 8'2"	+55/-55	0.0 psf	Yes	NCTL-210-3086-1 Max Panel Size: 3'0" x 6'7" Anchor Details: MA-FL0179
X Single (Slabs-CA/CH/EN)	O/S	Opaque	3'3" x 8'1"	+55/-55	10.5 psf	Yes	NCTL-210-3086-1 Max Panel Size: 3'0" x 6'7" Anchor Details: MA-FL0179
XX Double (Slabs-CA/CH/EN)	I/S	Opaque	6'4" x 6'10"	+50.5/-50.5	2.86 psf	Yes	NCTL-210-3087-1 Max Panel Size: 3'0" x 6'7" Anchor Details: MA-FL0178
XX Double (Slabs-CA/CH/EN)	O/S	Opaque	6'4" x 6'10"	+50.5/-50.5	8.25 psf	Yes	NCTL-210-3087-1 Max Panel Size: 3'0" x 6'7" Anchor Details: MA-FL0178

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be "MD", is written over a horizontal line.