



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG50-1854x1260 (73x50)-HS				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	11233	BUILDERS VINYL (V-2500) HS (FIN & FINLESS) (PVC)(OX)(OG)(INS GL) (MODIF)(REINF)(ASTM)	<u>FRAME</u> 1854 mm x 1260 mm (6'1" x 4'2")	<u>SASH</u> 930 mm x 1213 mm (3'1" x 4'0")


This Certification will expire **May 24, 2027 (extended from May 24, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **National Certified Testing Laboratories**

Report No.: **SJW2013-127**

Date of Reports: **August 5, 2013**

Evaluated for Certification: **August 10, 2021**


 Associated Laboratories, Inc.

Authorized for Certification: **August 10, 2021**



Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)