

# Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

Mfr ID: 413


For more Information visit [www.amscert.com](http://www.amscert.com)

Website: [www.kolbewindows.com](http://www.kolbewindows.com)

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1256.08	Ultra Inswing Door Sidelite Narrow Stiles, Single glaze & Insulated, EE, IPD4 (R&D 13030 & 13029)	101/I.S.2/A440-11	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-70 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1273mm	2507mm	ESP012898P-1406	3/20/2017	5/3/2026
413-H-1256.09	Ultra Inswing Door Sidelite Narrow Stiles, Single glaze & Insulated, EE, IPD4 (R&D 13030 & 13029)	101/I.S.2/A440-08	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-70 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1273mm	2507mm	ESP012898P-1406	3/20/2017	5/3/2026
413-H-1256.10	Ultra Inswing Door Sidelite Narrow Stiles, Single glaze & Insulated, EE, IPD4 (R&D 13030 & 13029)	ASTM E-1996 09/ ASTM E-1886-05	DP +65/-70 psf, Missile D, Wind Zone 4	1273mm	2507mm	ESP012898P-1406	3/20/2017	5/3/2026
413-H-1256.11	Ultra Inswing Door Sidelite Narrow Stiles, Single glaze & Insulated, EE, IPD4 (R&D 13030 & 13029)	ASTM E-1996-06 / ASTM E-1886-05	DP +65/-70 psf, Missile D, Wind Zone 4	1273mm	2507mm	ESP012898P-1406	3/20/2017	5/3/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)