

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011914.01-R11
DATE: 03/25/2014
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 05/21/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601</p>	<p>JELD-WEN "Design Pro/Smooth Pro Impact Approved/Studio" Fiberglass Opaque In-Swing or Out-Swing Side-Hinged Doors w/Glazed Sidelites</p> <p style="text-align: center;">Configuration: OXXO Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass</p> <p>IS Frame: W-3778mm(148.75") H-2487mm(97.93") OS Frame: W-3778mm(148.75") H-2470mm(97.25") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-606mm(23.87") H-1995mm(78.56")</p>

SPECIFICATION	PRODUCT RATING
<p>ASTM E283-04/E330-02 TAS 202-94 ASTM E1886-05/E1996-06 AAMA 1304-02</p>	<p>Design Pressure: +45/-45 psf Wind Zone 3 - Missile Level D Qualifies Configurations: OXX/XXO/OXXO</p>

Product Tested By: National Certified Testing Laboratories
 Report No: SJW2013-196/SJW2013-195/SJW2013-241/SJW2013-242/SJW2013-208-TAS/SJW2013-209-TAS/SJW2013-251/SJW2013-252/SJW2013-253/NCTL-210-3924-01/SJW2010-003/NCTL-210-3925-03/NCTL-210-3924-02/SJW2014-032/NCTL-210-3930-01/NCTL-210-3930-02/SJW2014-070/SJW2014-075/W-1666/W-1710/W1783/W-1799/W-1830/W-1861/W-1899/W-1904
 Expiration Date: **March 30, 2026**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122