

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011924.01-R10  
**DATE:** 03/27/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 05/21/2019

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b>  <b>3737 Lakeport Boulevard</b>  <b>Klamath Falls, OR 97601</b>	<b>JELD-WEN "Design Pro/Smooth Pro Impact Approved/Studio" Fiberglass Glazed In-Swing or Out-Swing Side-Hinged Door w/Glazed Sidelites</b>  Configuration: OXO Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass  IS Frame: W-2847mm(112.12") H-2487mm(97.93")  OS Frame: W-2847mm(112.12") H-2470mm(97.25")  Panel: W-908mm(35.75") H-2419mm(95.25")  DLO: W-606mm(23.87") H-1995mm(78.56")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04/E330-02</b> <b>TAS 202-94</b> <b>ASTM E1886-05/E1996-06</b> <b>AAMA 1304-02</b>	<b>Design Pressure: +45/-45 psf</b> <b>Wind Zone 3 - Missile Level D</b> Qualifies Configurations: XO/OXO

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-3918-01/NCTL-210-3924-02/SJW2013-137-TAS/SJW2013-241/SJW2013-242/SJW2013-208-TAS/SJW2013-209-TAS/SJW2013-234/SJW2013-235/SJW2013-251/SJW2013-252/SJW2013-253/NCTL-210-3924-01/NCTL-210-3925-03/SJW2010-003/SJW2014-032/NCTL-210-3930-01/NCTL-210-3930-02/SJW2014-068/SJW2014-071/SJW2014-069/SJW2014-079/W-1675W-1708/W-1783/W-1799/W-1861/W-1899/W-1904

Expiration Date: **March 30, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**