

# Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

Mfr ID: 413

For more Information visit [www.amscert.com](http://www.amscert.com)

Website: [www.kolbewindows.com](http://www.kolbewindows.com)

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1191.08	Heritage Fixed Casement, WW, HP Steel Reinforced Combination Mullled Above Two Heritage Operating Awnings. WW, HP Combination Mullled (R&D 11208)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 2438mm x 1829mm Type-FW; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	2438mm	1829mm	B9548.01-602-44	7/14/2017	8/29/2023
413-H-1191.09	Heritage Fixed Casement, WW, HP Steel Reinforced Combination Mullled Above Two Heritage Operating Awnings. WW, HP Combination Mullled (R&D 11208)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 1219mm x 914mm Type-AP; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1219mm	914mm	B9548.01-602-44	7/14/2017	8/29/2023
413-H-1191.10	Heritage Fixed Casement, WW, HP Steel Reinforced Combination Mullled Above Two Heritage Operating Awnings. WW, HP Combination Mullled (R&D 11208)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 2438mm Span/1375mm Tributary Width (96.00 in Span/54.13 in Trib Width) Type -MA (Horizontal reinforced combination mullion); DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1375mm trib width	2438mm span	B9548.01-602-44	7/14/2017	8/29/2023
413-H-1191.11	Heritage Fixed Casement, WW, HP Steel Reinforced Combination Mullled Above Two Heritage Operating Awnings. WW, HP Combination Mullled (R&D 11208)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 914mm Span/1219mm Tributary Width (36 in Span/48 in Trib Width) Type-MA (Vertical combination mullion); DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1219mm trib width	914mm span	B9548.01-602-44	7/14/2017	8/29/2023

# Hallmark® Certificate of Conformance and License (CCL)





Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

Mfr ID: 413  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website: [www.kolbewindows.com](http://www.kolbewindows.com)  
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)