

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011728-R3
DATE: 11/15/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 06/30/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "143 HR Non-Impact Fin" Vinyl Reinforced 72" x 60" Horizontal Roller Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.50") H-1511mm(59.50") Frame: W-886mm(34.87") H-1429mm(56.25") DLO: W-819mm(32.25") H-1384mm(54.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ANSI/AAMA/NWDA 101/I.S.2-97	HS-C50 1829 x 1524 (72 x 60) HS-C50 72 x 60 Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.36 psf)

Product Tested By: Architectural Testing Incorporated
Report No: 93704.01-501-47
Expiration Date: August 30, 2020

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.H.D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122