

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012135  
DATE: 09/15/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>10030 Bavaria Road</b> <b>Ft. Myers, FL 33913</b>	<b>Series "143.095 SS" Vinyl Flange</b> <b>(Rep) Horizontal Sliding Window</b>  Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1880mm(74") H-1829mm(72") Panel: W-908mm(35.75") H-1708mm(67.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 1880 x 1829 (74 x 72)-HS</b> <b>Design Pressure: 1676 Pa (35 psf)</b> <b>Negative Design Pressure: 1915 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 251 Pa(5.25 psf)</b>

Product Tested By: Certified Testing Laboratories, Inc.  
Report No: CTLA-3019W  
Expiration Date: **July 31, 2018**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122