

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012196.03-R3
DATE: 11/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176 SS" Vinyl Horizontal Sliding Window w/Flange Frame Configuration: XOX Glazing: IG-Ext-3/16" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" SGP Interlayer by DuPont/1/8" Annealed Glass and IG-Ext-3/16" Annealed Glass/Laminate-3/16" Annealed Glass/0.090" SGP Interlayer by DuPont/3/16" Annealed Glass Frame: W-2189mm(111") H-1600mm(63") Panel: W-717mm(28.25") H-1538mm(60.56")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ±2400 Pa (50 psf) Class LC-PG50 2819 x 1600 (111 x 63)-HS HS-LC50 2819 x 1600 (111 x 63) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3112 Pa (65 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 502 Pa(10.50 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3005W-2A/CTLA-3005W-2D
Expiration Date: June 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023