

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015126.02
DATE: 12/14/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern Arch
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176 HR PVB" Vinyl Horizontal Sliding Window Configuration: OX Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" PVB by Dupont Interlayer/1/8" Annealed Glass Frame: W-1854mm(73") H-1575mm(62") Sash: W-918mm(36.13") H-1508mm(59.38") DLO: W-832mm(32.75") H-1453mm(57.19")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 430 Pa (9.00 psf) Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-EAS-20-001
Expiration Date: **November 30, 2024**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122