

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015126.03
DATE: 11/09/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern Arch
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912 | Series "176 HRP 424 SGP" Vinyl Horizontal Sliding Window Configuration: XOX Operable Window Glazing: IG-3/16" Annealed Glass/1/8" Annealed Glass/0.090" SGP by Dupont Interlayer/1/8" Annealed Glass Fixed Window Glazing: IG-3/16" Annealed Glass/3/16" Annealed Glass/0.090" SGP by Dupont Interlayer/3/16" Annealed Glass Frame: W-2819mm(111") H-1930mm(76") Sash: W-719mm(28.31") H-1864mm(73.38") Fixed DLO: W-1295mm(51") H-1834mm(72.19") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------|---|
| TAS 201/202/203-94 | Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf) Large Missile Impact Rated |

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-EAS-22-001
Expiration Date: September 30, 2026

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com