

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011795.02-R6  
**DATE:** 01/24/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Plyco  
**CODE:** 765-1  
**REVISION DATE:** 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>Plyco Corporation</b><br><b>dba Modern Door Corporation</b><br><b>500 Industrial Road/PO Box 386</b><br><b>Elkhart Lake, WI 53020</b> | <b>Series "92 TB" Thermally Broken</b><br><b>Opaque Out-Swing Steel</b><br><b>Side-Hinged Door</b><br><br>Configuration: X<br><br>Frame: W-1314mm(51.75") H-2188mm(86.12")<br>Panel: W-1213mm(47.75") H-2113mm(83.18")<br>DLO: W-527mm(20.75") H-1492mm(58.75") |

| SPECIFICATION       | PRODUCT RATING   |
|---------------------|--|
| <b>ASTM E330-02</b> | <b>Design Pressure: 2160 Pa (45 psf)</b><br><b>Negative Design Pressure: 2160 Pa (45 psf)</b><br>Qualifies Configurations: X |

Product Tested By: Architectural Testing, Inc.  
Report No: C9317.01-602-44 (Specimen 3)/W-1649/W-1911  
Expiration Date: **November 30, 2026**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)