

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013981.19-R2  
**DATE:** 04/04/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 03/19/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Architectural" Opaque</b> <b>Fiberglass In-Swing Side-Hinged Door</b> <b>w/Sidelites</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1982mm(78.06") H-2485mm(97.81")  Panel: W-1059mm(41.68") H-2412mm(94.94") Sidelite: W-403mm(15.88") H-2402mm(94.56")  DLO: W-180mm(7.06") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04(12)/E330/E330M-14</b> <b>ASTM E331-00(09)(16)</b>	<b>Design Pressure: 2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</b>

Product Tested By: Intertek Group, PLC  
Report No: H9982.12-301-47/W-1856  
Expiration Date: **February 28, 2027**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122