

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.61-R1
DATE: 03/10/2020
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Opaque Fiberglass In-Swing Side-Hinged Double Door Assembly Configuration: XX Frame: W-1873mm(73.75") H-2080mm(81.88") Panel: W-908mm(35.75") H-2003mm(78.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG60 1873 x 2080 (73 x 82)-LW SHD Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.0 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL 310-19-031/J788.01-301-47
Expiration Date: **September 30, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com