

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.01-R2
DATE: 02/27/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 03/22/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Opaque Fiberglass In-Swing Side-Hinged Door w/Sidelites Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass Frame: W-1828mm(71.94") H-2075mm(81.69") Panel: W-905mm(35.63") H-2002mm(78.81") Sidelite: W-405mm(15.94") H-2005mm(78.94") DLO: W-180mm(7.06") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330/E330M-14 ASTM E331-00(09)(16) ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek Group, PLC
Report No: H9982.10-301-47
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122