

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.08-R2
DATE: 03/01/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 03/22/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | Series "Architectural" Full Lite Fiberglass Out-Swing Side-Hinged Door w/Sidelites & Standard Sill Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass Frame: W-1833mm(72.19") H-2448mm(96.38") Panel: W-908mm(35.75") H-2413mm(95") Sidelite: W-404mm(15.88") H-2413mm(95") DLO: W-538mm(21.19") H-1603mm(63.13") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| ASTM E330/E330M-14 ASTM E283-04(12)/E547-00(09)(16) ASTM E1886-05/13a ASTM E1996-09/12a/14a | Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 3 - Missile Level D |

Product Tested By: Intertek Group, PLC
Report No: H9984.07-301-47
Expiration Date: March 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122