

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.30-R1
DATE: 04/08/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | Series "Architectural" Opaque Fiberglass In-Swing Side-Hinged Door Configuration: X Frame: W-950mm(37.38") H-2042mm(80.38") Panel: W-908mm(35.75") H-2009mm(79.13") DLO: W-537mm(21.13") H-410mm(16.13") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/13a ASTM E1996-09/12a/14a | Class LC-PG50 950 x 2086 (37 x 82)-LW SHD Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (8.00 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 3 - Missile Level D |

Product Tested By: Intertek Group, PLC
Report No: J3252.01-301-47
Expiration Date: March 31, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com