

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.42-R1
DATE: 05/22/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Glazed Fiberglass Out-Swing Side-Hinged Door Configuration: X Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray PVB Interlayer/1/8" Annealed Glass Frame: W-950mm(37.38") H-2042mm(80.38") Panel: W-908mm(35.75") H-2009mm(79.13") DLO: W-537mm(21.13") H-410mm(16.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/13a ASTM E1996-09/12a/14a	Class LC-PG50 950 x 2042 (37 x 80)-SHD X Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 3 - Missile Level D

Product Tested By: Intertek Group, PLC
Report No: J3362.01-301-47/J3360.01-301-47
Expiration Date: **January 31, 2028**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com