

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.54-R1
DATE: 12/10/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Opaque Fiberglass In-Swing Side-Hinged Double Door Assembly Configuration: XX Frame: W-2185mm(86") H-2480mm(97.63") Panel: W-1061mm(41.75") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
ASTM /E330-02(10) ASTM E283-04(12)/E331-00(09) ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.0 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: J7895.01-301-47
Expiration Date: May 31, 2028

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com