

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011639  
DATE: 08/28/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: All Seasons  
CODE: 353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>1293 N. Harvey Mitchell Parkway</b> <b>Bryan, TX 77803</b>	<b>Series "8065"</b> <b>Aluminum Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Heat Strengthened)  Frame: W-1524mm(60") H-2515mm(99") DLO: W-1435mm(56.5") H-2426mm(95.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG120 1524 x 2515 (60 x 99)-FW</b> <b>Design Pressure: 5746 Pa (120 psf)</b> Water Penetration Resistance Test Pressure: 718 Pa (15 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: C9913.01-801-44  
Expiration Date: **July 31, 2017**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122