

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011641-R5
DATE: 08/28/2013
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 353-2
REVISION DATE: 01/22/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
All Seasons Commercial Division, Inc. 400 Ambassador Row Longview, TX 75604	Series "E2500FF" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1524mm(60") H-2515mm(99") DLO: W-1429mm(56.25") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG100 1524 x 2515 (60 x 99)-FW Design Pressure: 4800 Pa (100 psf) Water Penetration Resistance Test Pressure: 580 Pa (12 psf)

Product Tested By: Architectural Testing, Inc.
Report No: A5246.01-801-44
Expiration Date: November 30, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com