

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011644  
DATE: 08/28/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: All Seasons  
CODE: 353-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>1293 N. Harvey Mitchell Parkway</b> <b>Bryan, TX 77803</b>	<b>Series "E2500"</b> <b>Aluminum Out-Swing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36") H-1524mm(60") Vent: W-867mm(34.31") H-1480mm(58.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class AW-PG95 914 x 1524 (36 x 60)-C</b> <b>C-AW95 914 x 1524 (36 x 60)</b> <b>Design Pressure: 4560 Pa (95 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15904-1  
Expiration Date: March 31, 2017

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**