NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI011644.01	
08/30/2013	
Structural	
All Seasons	
353-1	

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
All Seasons Commercial Division, Inc.	Series "E3250COS"	
1293 N. Harvey Mitchell Parkway	Aluminum Out-Swing Casement Window	
Bryan, TX 77803		
	Configuration: X Glazing: Insulating Glass (Annealed)	
	Frame: W-914mm(36") H-1524mm(60")	
	Vent: W-867mm(34.31") H-1480mm(58.25")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class AW-PG95 914 x 1524 (36 x 60)-C C-AW95 914 x 1524 (36 x 60) Design Pressure: 4560 Pa (95 psf) Water Penetration Resistance Test Pressure: 580 Pa (12 psf)

Product Tested By:National Certified Testing LaboratoriesReport No:NCTL-110-15904-1/W-1619Expiration Date:March 31, 2017

<u>017</u>

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122