

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011644.01-R3  
**DATE:** 08/28/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** All Seasons  
**CODE:** 353-2  
**REVISION DATE:** 01/11/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Window &amp; Door Mfg., Inc.</b> <b>400 Ambassador Row</b> <b>Longview, Texas 75604</b>	<b>Series "E3250"</b> <b>Aluminum Out-Swing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36") H-1524mm(60") Vent: W-867mm(34.31") H-1480mm(58.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class AW-PG95 914 x 1524 (36 x 60)-C</b> <b>C-AW95 914 x 1524 (36 x 60)</b> <b>Design Pressure: 4560 Pa (95 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15904-1/W-1619  
Expiration Date: **March 31, 2027**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)