

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012033-R6
DATE: 06/22/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "M85" Aluminum Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-2057mm(81") Sash: W-1270mm(50") H-1029mm(40.5") DLO: W-1181mm(46.5") H-933mm(36.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG50 1321 x 2057 (52 x 81)-H H-C50 1321 x 2057 (52 x 81) Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 95255.02-602-44-R1/95255.01-602-44-R1
Expiration Date: **June 30, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com